



**OFFICE OF THE EXECUTIVE ENGINEER GANGA JAL PROJECT UNIT,
U.P. JAL NIGAM (URBAN) 120 MLD W.T.P. LABORATORY,
PRATAP VIHAR, GHAZIABAD-201009**

Letter No. 748 / Testing

160

Dated 8/05/2026

To,

Principal
Golden Valley International School
Roza Jalalpur, Near Main Mkt. Gr. Noida (W) 201009

Sub :- Physical and Chemical analysis of water sample

Dear Sir,

The water analysis report for the water sample (01 No.) sent along with your letter No. GS/18 Dated 14.05.2026 the physical and chemical analysis report is enclosed with this letter.

Water Sample From Golden Valley International School :- 1 No.
Roza Jalalpur, Near Main Mkt. Gr. Noida

Total :- 1 No.

Enclosers : As Above.


Executive Engineer

	WATER TESTING LABORATORY 120 MLD, WATER TREATMENT PLANT, GANGA JAL PROJECT, PRATAP VIHAR, GHAZIABAD- 201009	 TC-15179
	TEST REPORT	

Lab Address	120 MLD Water Treatment Plant Ganga Jal Project, Pratap Vihar, Ghaziabad		
Customer Name and Address	Principal Golden Valley International School Roza Jajalpur Near Main Mkt. Gr. Noida (W)	Lab Temperature During Testing	26.3°C
Test Report No.	UPJN/2025-26/B/213	Test Start Date:	16.05.2026
Sample Description	Water Sample From G.V. International School Roza Jajalpur Near Main Mkt. Gr. Noida (W)	Test Completion Date:	19.05.2026
Specification	IS 10500:2012 Amendment No. 2		
Sample Packaging Details	Sample Sealed (01 Litre)	Issued Date:	20.05.2026
Environment conditions at Lab During Testing	25°C ± 3°C	Sample code	UPJN/2025-26/B/213

Sr. No.	Test Parameters/ Unit	Test Result	Requirement as Per IS 10500:2012		Test Method
			Acceptable Limit	Permissible Limit	
1	pH	6.96	6.50 - 8.50	No Relaxation	IS: 3025 Pt-11:2022
2	Turbidity, NTU	0.28	1.0	5.0	IS: 3025 Pt-10:2024
3	Total Hardness (as CaCO ₃) mg/l	204.00	200	600	IS: 3025 Pt-21:2023
4	Calcium (as Ca) mg/l	22.44	75	200	IS: 3025 Pt-40:2024
5	Magnesium (as Mg) mg/l	35.93	30	100	IS: 3025 Pt-46:2023
6	Chloride (as Cl) mg/l	111.96	250	1000	IS: 3025 Pt-32:2019
7	Total Dissolved Solids, mg/l	510.00	500	2000	IS: 3025 Pt-16:2023
8	Total Solids, mg/l	542.00	--	--	IS: 3025 Pt-15:2009
9	Conductivity, µS/cm	1006.00	--	--	IS:3025, Pt-14:2019

DECLARATION:

- This test report refers to items submitted for testing only.
- This test report shall not be re-produced except in full unless written permission for the publication of an approved abstract has been obtained from WTL.
- The test results reported in this report are valid at the time and under the stated conditions of testing
- Sampling is not done by WTL Sample is provided by the customer.
- Sample shall be retained at the lab maximum for 15 days (in case any retesting needs to be initiated)

--- End of Report---

Reviewed By:



Name: Hari Sharan

Designation: Chemist

Doc. NO. WTL /F/TR/01, Rev- 00

Authorized Signatory



Kishan Singh Adhikari

Designation: Technical Head

Page-1 of 1



WATER TESTING LABORATORY

120 MLD, WATER TREATMENT PLANT, GANGA JAL
PROJECT, PRATAP VIHAR GHAZIABAD -201009



TEST REPORT

Lab Address	120 MLD Water Treatment Plant, Ganga Jal Project, Pratap Vihar, Ghaziabad.		
Customer Name and Address	Principal Golden Valley International School Roza Jajalpur Near Main Mkt. Gr. Noida (W)	Lab Temperature During Testing	26.3°C
Test Report No.	UPJN/2025-26/B/213	Test Start Date:	16.05.2026
Sample Description	Water Sample From G.V. International School Roza Jajalpur Near Main Mkt. Gr. Noida (W)	Test Completion Date	19.05.2026
Specification	IS 10500:2012 Amendment No. 2	Sample Code No.	UPJN/2025-26/B/213
Sample Packaging Details	Sample Sealed (01 Litre)	Issued Date	20.05.2026
Environment conditions at Lab During Testing	25°C $\pm$ 3°C	Sample collected By	Sh. Man Mohan Sharma

Test Results: Physico-Chemical Characteristics As per IS 10500 : 2012 as Amendment No. 2

Sl.No.	Parameter	Expressed as	Analysed Result	Acceptable Limit	Permissible Limit
1	Sulphate (as SO ₄)	mg/l	32.00	200	400
2	Fluoride (as F)	mg/l	1.4	1.0	1.5
3	Nitrate (as NO ₃)	mg/l	5.6	45	No relaxation
4	Iron (as Fe)	mg/l	BDL	1.0	No relaxation
5	Residual Chlorine	mg/l	Nil	0.2	1.0

- Note :-**
- (i) Figures in Col-5 are the limits up to which drinking water is acceptable to the consumers.
 - (ii) Figures in excess of Col-6 render the water not acceptable, but still may be tolerated (up to the limit indicated in the Col-6) in the absence of alternative and better source.
 - (iii) The water sample is not collected by us
 - (iv) BDL- Below Detection Limit.

-- End of Report--

Reviewed By

Name: Hari Sharan

Designation: Chemist

Authorized Signatory

Name: Kishan Singh Adhikari

Designation: Technical Head